

# National Construction Code May 2019 Requirements for Large Access Doors



## Wind Regions A & B

Closed Design, non-rated doors, non-compliant with AS/ NZS 1170.2 - 2011 AMDT 4 clause 5.3.2.2.



“CLOSED” design relies on rated doors – internal pressure typically +0.00 or +0.20



“OPEN” design relies on portals and purlins to withstand wind pressure if Non-rated door used Internal pressure typically +0.7 - 0.65

